

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	3847.7 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	42.2V x 42.6H
	At 50% of Imax	16.7V x 17.0H
	At 90% of Imax	6.6V x 6.5H

Beam Flux	Total	723.0 lumens per klm.
	To 10% of Imax	466.8 lumens per klm.
	To 50% of Imax	199.6 lumens per klm.
	To 90% of Imax	43.6 lumens per klm.

Upward LOR	0.0 %
Downward LOR	72.3 %


Luminaire Efficiency (Light Output Ratio)	71.9 %
---	--------

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL	96GRF1/31524	Imax (cd)	1039
NOMINAL POWER (W)	3	AVAILABILITY (%)	46.7
RATED VOLTAGE (V)	230	Avai. FLUX (lm)	126.0
NOMINAL FLUX (lm)	270	LOR (%)	71.9
LAMPS INSIDE	1	TOTAL FLUX (lm)	194.2
TEST VOLTAGE (V)	230	θ @50% (H,V)	17,17DEG

VERTICAL (DEG)	AREA FLUX DIAGRAM																UNIT:lm		Φ t	Φ a
	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.03	0.00
90	0.00	0.00	0.00	0.00	0.01	0.01	0.02	0.03	0.03	0.03	0.03	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.21	0.00
80	0.00	0.00	0.00	0.01	0.02	0.04	0.06	0.09	0.10	0.11	0.10	0.08	0.05	0.03	0.01	0.00	0.00	0.00	0.71	0.00
70	0.00	0.00	0.01	0.03	0.06	0.10	0.14	0.18	0.20	0.21	0.20	0.17	0.12	0.06	0.03	0.01	0.00	0.00	1.53	0.00
60	0.00	0.00	0.02	0.05	0.12	0.19	0.28	0.36	0.41	0.43	0.38	0.30	0.21	0.11	0.05	0.02	0.00	0.00	2.92	0.00
50	0.00	0.00	0.03	0.08	0.19	0.33	0.50	0.74	0.95	0.96	0.72	0.47	0.31	0.16	0.07	0.02	0.00	0.00	5.54	0.00
40	0.00	0.01	0.03	0.12	0.26	0.45	0.83	1.55	2.25	2.23	1.56	0.83	0.42	0.21	0.08	0.03	0.01	0.00	10.9	0.60
30	0.00	0.01	0.04	0.14	0.31	0.59	1.41	3.39	6.34	5.84	3.10	1.42	0.58	0.26	0.10	0.03	0.01	0.00	23.6	16.1
20	0.00	0.01	0.05	0.15	0.33	0.71	1.99	6.15	20.3	18.1	5.23	1.94	0.71	0.29	0.11	0.04	0.01	0.00	56.1	50.1
10	0.00	0.01	0.05	0.14	0.32	0.71	1.99	5.87	18.2	15.7	5.15	1.93	0.73	0.29	0.11	0.04	0.01	0.00	51.3	45.3
0	0.00	0.01	0.04	0.13	0.28	0.59	1.39	3.15	5.30	5.10	3.00	1.39	0.60	0.26	0.11	0.04	0.01	0.00	21.4	13.7
-10	0.00	0.01	0.04	0.10	0.21	0.42	0.81	1.42	1.99	1.97	1.42	0.82	0.43	0.22	0.09	0.03	0.01	0.00	9.98	0.13
-20	0.00	0.00	0.03	0.08	0.15	0.27	0.45	0.65	0.80	0.82	0.68	0.48	0.31	0.17	0.08	0.03	0.00	0.00	4.98	0.00
-30	0.00	0.00	0.02	0.05	0.10	0.15	0.24	0.34	0.41	0.44	0.40	0.32	0.21	0.12	0.05	0.02	0.00	0.00	2.88	0.00
-40	0.00	0.00	0.01	0.03	0.06	0.08	0.11	0.15	0.20	0.23	0.23	0.18	0.11	0.06	0.03	0.01	0.00	0.00	1.49	0.00
-50	0.00	0.00	0.00	0.01	0.03	0.04	0.05	0.06	0.08	0.09	0.08	0.07	0.04	0.03	0.01	0.01	0.00	0.00	0.61	0.00
-60	0.00	0.00	0.00	0.00	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.02	0.01	0.01	0.00	0.00	0.00	0.00	0.17	0.00
-70	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02	0.00
-80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
HORIZONTAL (DEG)																				
Φ t	0.00	0.06	0.37	1.13	2.46	4.71	10.3	24.1	57.5	52.3	22.3	10.4	4.85	2.27	0.94	0.32	0.06	0.00	194	---
Φ a	0.00	0.00	0.00	0.00	0.00	0.00	0.66	16.2	50.5	44.9	13.5	0.24	0.00	0.00	0.00	0.00	0.00	0.00	---	126

one-half-peak spread: U:7.5,D:9.3 , L:9.3,R:7.8

NEMA Beam Type: Type 3

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456


Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

ISOCANDELA DIAGRAM

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:25.3°C
Operators:
Test Date:01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 01 September 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

AAI Figure

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:



Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature: 25.3°C

Operators:

Test Date: 01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity: 65.0%

Test Distance: 6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:

Table--1

UNIT: cd

H(DEC) V(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
-85	0.00	0.00	0.00	0.01	0.02	0.02	0.01	0.03	0.05	0.04	0.03	0.05	0.06	0.05	0.04	0.03	0.02	0.01	0.00
-80	0.00	0.00	0.00	0.02	0.05	0.06	0.08	0.11	0.14	0.14	0.14	0.16	0.18	0.17	0.15	0.16	0.17	0.15	0.14
-75	0.00	0.00	0.00	0.04	0.09	0.12	0.14	0.22	0.30	0.35	0.40	0.45	0.51	0.53	0.53	0.56	0.59	0.60	0.60
-70	0.00	0.00	0.02	0.07	0.13	0.20	0.31	0.45	0.58	0.70	0.79	0.91	0.98	1.05	1.09	1.18	1.30	1.42	1.53
-65	0.00	0.00	0.04	0.10	0.20	0.35	0.54	0.76	0.98	1.20	1.43	1.60	1.71	1.80	1.96	2.16	2.36	2.55	2.70
-60	0.00	0.00	0.06	0.12	0.30	0.55	0.82	1.14	1.52	1.91	2.19	2.32	2.48	2.72	3.04	3.36	3.67	3.96	4.19
-55	0.00	0.01	0.07	0.19	0.45	0.76	1.12	1.64	2.24	2.61	2.90	3.16	3.56	3.98	4.43	4.97	5.55	6.15	6.70
-50	0.00	0.01	0.09	0.26	0.60	0.97	1.53	2.31	2.95	3.44	3.92	4.42	5.04	5.70	6.62	7.97	8.98	9.82	10.6
-45	0.00	0.02	0.10	0.35	0.74	1.21	2.02	2.97	3.72	4.43	5.14	6.03	7.06	8.66	10.3	11.6	12.8	13.6	14.2
-40	0.00	0.03	0.12	0.45	0.88	1.56	2.55	3.64	4.61	5.64	6.75	8.33	10.1	12.0	14.0	15.5	16.9	17.9	18.4
-35	0.00	0.03	0.15	0.54	1.05	1.90	3.13	4.34	5.56	6.95	8.71	10.6	12.8	15.7	18.8	21.8	23.9	25.3	26.6
-30	0.00	0.04	0.18	0.61	1.22	2.26	3.69	5.01	6.56	8.35	10.6	13.1	16.7	22.0	26.0	30.8	35.2	38.7	40.4
-25	0.00	0.04	0.20	0.68	1.40	2.59	4.22	5.71	7.57	9.70	12.6	16.3	22.4	28.3	37.3	47.1	56.3	62.7	64.7
-20	0.00	0.04	0.22	0.74	1.55	2.94	4.69	6.37	8.59	11.3	14.8	20.0	27.3	37.7	52.0	70.9	90.8	105	110
-15	0.00	0.05	0.23	0.80	1.67	3.23	5.08	7.04	9.54	13.0	16.8	22.7	33.1	49.3	72.1	106	137	165	174
-10	0.00	0.05	0.24	0.84	1.75	3.47	5.41	7.57	10.2	14.1	18.1	25.5	39.0	60.7	95.8	145	218	315	337
-5	0.00	0.05	0.24	0.86	1.80	3.63	5.66	7.92	10.7	14.7	18.9	27.6	42.9	69.2	115	185	356	651	765
0	0.00	0.05	0.24	0.88	1.82	3.72	5.83	8.12	11.0	15.1	19.3	27.9	44.0	72.2	123	206	449	895	1039
5	0.00	0.05	0.24	0.88	1.80	3.58	5.82	8.17	11.2	15.2	19.2	27.1	42.6	68.7	117	195	388	743	873
10	0.00	0.05	0.23	0.86	1.76	3.37	5.70	8.06	11.1	15.0	18.7	25.3	38.8	60.6	97.9	157	248	396	456
15	0.00	0.05	0.22	0.82	1.68	3.09	5.43	7.77	10.8	14.6	17.8	22.7	32.9	49.4	74.5	112	157	193	199
20	0.00	0.05	0.21	0.76	1.58	2.77	4.94	7.35	10.1	13.6	16.4	20.0	26.5	38.7	54.5	75.5	98.7	116	119
25	0.00	0.04	0.19	0.69	1.46	2.43	4.23	6.65	9.45	12.1	14.9	17.8	21.9	29.0	39.4	51.1	63.1	72.6	75.0
30	0.00	0.04	0.17	0.59	1.31	2.17	3.49	5.57	8.23	10.7	13.2	15.8	18.2	22.0	28.5	35.3	41.6	45.0	47.6
35	0.00	0.04	0.15	0.49	1.14	1.88	2.88	4.44	6.73	8.92	11.0	13.1	15.7	17.5	20.5	24.9	28.8	31.6	32.5
40	0.00	0.03	0.12	0.40	0.94	1.61	2.38	3.51	5.24	6.94	8.56	10.4	12.1	14.2	15.9	17.1	18.9	20.2	21.1
45	0.00	0.03	0.11	0.30	0.74	1.31	1.95	2.73	3.91	5.35	6.42	7.61	8.97	9.95	11.1	11.7	12.7	13.2	13.1
50	0.00	0.02	0.10	0.22	0.52	1.02	1.53	2.09	2.87	4.03	4.92	5.52	6.31	7.08	7.74	8.28	8.75	9.10	9.33
55	0.00	0.02	0.08	0.17	0.36	0.72	1.13	1.55	2.05	2.76	3.53	4.13	4.52	4.95	5.48	5.93	6.28	6.57	6.76
60	0.00	0.01	0.07	0.11	0.22	0.44	0.76	1.08	1.40	1.77	2.20	2.69	3.15	3.51	3.77	4.08	4.50	4.77	4.92
65	0.00	0.01	0.06	0.09	0.14	0.26	0.45	0.67	0.87	1.09	1.34	1.61	1.95	2.29	2.66	2.91	3.10	3.28	3.43
70	0.00	0.01	0.04	0.06	0.08	0.15	0.25	0.38	0.50	0.64	0.79	0.96	1.12	1.34	1.60	1.86	2.09	2.17	2.19
75	0.00	0.01	0.03	0.04	0.05	0.08	0.13	0.19	0.26	0.35	0.45	0.52	0.59	0.70	0.80	0.87	0.92	0.95	0.97
80	0.00	0.01	0.02	0.02	0.02	0.04	0.07	0.08	0.09	0.13	0.17	0.22	0.26	0.31	0.36	0.38	0.39	0.41	0.42
85	0.00	0.00	0.01	0.01	0.00	0.01	0.03	0.03	0.02	0.04	0.06	0.06	0.05	0.08	0.10	0.07	0.05	0.06	0.07
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.01	0.01	0.01	0.00	0.00	0.00

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

NAME: 96GRF1/31524	TYPE: 96GRF1/31524	WEIGHT: 1
SPEC.:	DIM.: F 100 x 80	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: 3 Circle	Shielding Angle:

Table--2

UNIT: cd

H(DEC) V(DEC)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
-85	0.03	0.06	0.05	0.04	0.05	0.06	0.05	0.03	0.04	0.05	0.03	0.01	0.02	0.03	0.01	0.00	0.00	0.00	
-80	0.16	0.17	0.17	0.16	0.17	0.18	0.16	0.13	0.13	0.13	0.11	0.08	0.07	0.06	0.02	0.01	0.01	0.01	
-75	0.64	0.66	0.64	0.62	0.60	0.57	0.52	0.46	0.39	0.33	0.25	0.17	0.14	0.11	0.06	0.01	0.01	0.01	
-70	1.59	1.60	1.53	1.43	1.28	1.14	1.00	0.87	0.77	0.64	0.49	0.35	0.24	0.16	0.09	0.03	0.01	0.01	
-65	2.77	2.79	2.71	2.55	2.26	1.98	1.69	1.45	1.23	1.01	0.78	0.57	0.39	0.25	0.13	0.05	0.02	0.02	
-60	4.42	4.63	4.88	4.61	4.11	3.38	2.70	2.19	1.82	1.52	1.17	0.83	0.57	0.35	0.17	0.07	0.02	0.02	
-55	7.42	7.74	7.68	7.29	6.62	5.57	4.32	3.44	2.71	2.26	1.70	1.15	0.78	0.47	0.24	0.10	0.03	0.03	
-50	11.0	11.0	10.7	10.0	9.07	7.80	6.50	5.19	3.97	3.12	2.44	1.58	1.00	0.60	0.31	0.12	0.04	0.04	
-45	14.4	14.2	13.6	12.7	11.6	10.2	8.36	6.81	5.38	4.17	3.07	2.13	1.23	0.74	0.38	0.14	0.05	0.05	
-40	18.3	18.0	17.1	15.8	14.2	12.4	10.3	8.29	6.60	5.05	3.64	2.72	1.58	0.87	0.45	0.17	0.06	0.06	
-35	26.5	25.0	22.0	19.6	17.4	14.8	12.0	9.81	7.74	5.91	4.18	3.02	1.90	1.02	0.52	0.20	0.06	0.06	
-30	39.3	37.1	32.6	27.0	21.6	17.9	14.2	11.3	8.83	6.71	4.80	3.30	2.22	1.14	0.59	0.23	0.07	0.07	
-25	62.2	55.8	46.9	37.7	29.2	21.9	16.8	12.7	9.98	7.42	5.30	3.58	2.46	1.29	0.66	0.26	0.07	0.07	
-20	103	88.6	69.6	52.5	38.5	28.2	19.6	14.3	10.9	8.08	5.68	3.83	2.60	1.43	0.71	0.28	0.08	0.08	
-15	163	133	99.8	71.1	49.5	33.9	23.0	16.2	11.6	8.64	6.00	4.02	2.72	1.52	0.75	0.29	0.08	0.08	
-10	277	198	134	91.4	59.4	38.9	26.8	18.0	12.4	8.97	6.16	4.15	2.81	1.57	0.78	0.30	0.08	0.08	
-5	532	285	170	107	67.8	43.0	28.8	18.8	13.0	9.12	6.18	4.20	2.86	1.59	0.79	0.30	0.09	0.09	
0	739	346	183	112	70.5	43.9	29.3	18.5	13.3	9.08	6.05	4.18	2.86	1.57	0.80	0.30	0.09	0.09	
5	648	319	169	107	68.4	42.5	28.0	18.2	13.0	8.93	5.87	4.11	2.83	1.56	0.78	0.29	0.09	0.09	
10	355	210	135	92.9	60.6	38.9	25.2	17.5	12.3	8.54	5.58	3.99	2.74	1.51	0.76	0.28	0.09	0.09	
15	175	137	104	73.4	50.1	33.3	21.9	16.5	11.5	8.09	5.22	3.81	2.61	1.44	0.72	0.27	0.08	0.08	
20	111	95.3	74.4	55.0	39.5	26.7	19.2	14.9	10.7	7.45	4.90	3.60	2.42	1.34	0.68	0.25	0.08	0.08	
25	72.4	63.5	51.8	40.3	29.0	21.2	16.8	13.1	9.94	6.49	4.58	3.35	2.19	1.21	0.62	0.23	0.08	0.08	
30	46.7	42.4	36.3	27.6	21.4	17.4	14.3	11.6	8.75	5.77	4.17	3.04	1.94	1.07	0.56	0.21	0.07	0.07	
35	31.8	28.2	23.1	19.9	16.8	14.5	12.2	10.1	7.26	5.07	3.73	2.64	1.65	0.94	0.48	0.19	0.07	0.07	
40	20.3	18.7	16.9	15.2	13.6	11.9	10.5	8.44	6.03	4.30	3.18	2.18	1.41	0.79	0.40	0.16	0.06	0.06	
45	13.7	13.5	12.8	11.8	10.8	9.82	8.38	6.78	4.92	3.51	2.58	1.79	1.16	0.65	0.30	0.14	0.06	0.06	
50	9.61	9.71	9.76	9.26	8.52	7.52	6.42	5.13	3.74	2.75	2.01	1.43	0.91	0.49	0.22	0.12	0.05	0.05	
55	6.94	6.99	6.85	6.54	6.22	5.59	4.82	3.67	2.72	2.07	1.55	1.09	0.66	0.34	0.18	0.11	0.04	0.04	
60	5.01	4.99	4.84	4.64	4.38	3.89	3.16	2.41	1.94	1.50	1.12	0.75	0.41	0.20	0.13	0.09	0.03	0.03	
65	3.46	3.43	3.29	3.07	2.74	2.32	1.88	1.55	1.23	0.96	0.69	0.43	0.23	0.14	0.11	0.07	0.03	0.03	
70	2.12	2.01	1.85	1.65	1.44	1.23	1.06	0.87	0.70	0.50	0.36	0.21	0.14	0.10	0.08	0.05	0.02	0.02	
75	0.96	0.94	0.88	0.81	0.71	0.61	0.52	0.43	0.32	0.21	0.17	0.13	0.09	0.06	0.05	0.03	0.02	0.02	
80	0.40	0.38	0.36	0.34	0.29	0.23	0.19	0.16	0.11	0.08	0.08	0.08	0.05	0.02	0.02	0.02	0.01	0.01	
85	0.07	0.07	0.08	0.09	0.07	0.04	0.05	0.06	0.04	0.02	0.02	0.03	0.01	0.00	0.01	0.01	0.01	0.01	
90	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

C Range: 0 - 360DEG

C Interval: 10.0DEG

Test Speed: HIGH

Temperature:25.3°C

Operators:

Test Date:01 September 2022

γ Range: 0 - 90DEG

γ Interval: 2.5DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456

Humidity:65.0%

Test Distance:6.265m [K=1.0000]

Remarks: